

Water Service Request for:

Single Family Homes - Will Serve Letter required.

- Within City Limits meter must be placed per W-01, be advised there are components to be supplied by developer/owner/contractor.
- Outside City Limits (County) must place meter per W-01 and an RP per W-39.
 - The only exception would be mobile homes where W-39 is not needed.

Property corners are to be staked by a **California Licensed Surveyor** if the service is to be placed by District Crews. If the property is outside city limits the meter must be placed within an easement, right-of-way, or offer of dedication of right-of-way. You will need to contact the county (Land Use Services, (909) 387-8311) for their requirements and conditions regarding street dedication. An APN will be needed.

*** FIRE Sprinkler calculations are required if a contractor is requesting a ¾-inch meter.

Tract Homes

Tracts larger than 20 lots require a Feasibility Study prior to the issuance of a Will Serve Letter. In addition, Water Improvement Plans are required, please refer to Plan Check Checklist.

LMAD's require a water meter per W-01 or W-03 and an RP per W-31.

Refer to **Single Family Homes**.

*** Fire hydrant spacing is 300 feet from existing hydrants, if any. Blue Reflective Markers for Hydrants are to be placed and maintained per [200800422 fire 508 5 2](#). Water Plans are to include this standard.

Commercial/Industrial

Buildings larger than 1 million square feet require a WSA prior to the issuance of a Will Serve Letter. In addition, Water Improvement Plans are required, please refer to Plan Check Checklist.

Irrigation Water Service requires a separate water meter per W-01 or W-03 and an RP per W-31.

Domestic Service meters are to be placed per W-01, W-03, W-04 or W-05 and an RP per W-39 or W-30.

*** Fire hydrant spacing is 300 feet from existing hydrants, if any. Blue Reflective Markers for Hydrants are to be placed and maintained per [200800422 fire 508 5 2](#). Water Improvement Plans are to include this standard. Fire Service RP is to be placed per W-28.

NOTE: Sometimes existing Water Service lines are required to be upgraded by installing RP devices. A simple exhibit is required for Domestic/Irrigation services. If a Fire service requires an RP, a formal plan submittal is required. An existing by-pass meter will be re-used and existing vaults can be abandoned in place at the discretion of the Public Works Inspector.

[O:\Water\ - Counter Questions](#)