



NOTES:

- A. ALL SERVICE MATERIAL SHALL BE NEW; REFER TO VWD STD. DWG. W-10 FOR PLACEMENT OF ANGLE STOP AND METER BOX.
- B. ITEMS 10, 11, 12 AND 13 TO BE INSTALLED BY THE CONTRACTOR AFTER THE METER HAS BEEN SET, UNLESS SERVICE INSTALLATION WAS PAID FOR.
- C. ALL METERS REQUIRE A DEPARTMENT OF PUBLIC HEALTH-APPROVED, OWNER INSTALLED, REDUCED PRESSURE BACKFLOW PREVENTION DEVICE IN ACCORDANCE WITH W-39, TO BE TESTED PRIOR TO SERVICE ACTIVATION.

ITEM	DESCRIPTION	APPROVED MATERIAL LIST NUMBER
1	"MAIN SIZE" x 2" SERVICE SADDLE	7-B
2	2" CORP. STOP (MIP x COMPRESSION)	2-D
3	1 1/2" OR 2" COPPER TUBING PER RESPECTIVE METER SIZE	1-D
4	2" SERVICE LATERAL (LENGTH VARIES)	1-D
5	2" - 45° FITTING (SOLDER)	6-D
6	2" - 90° ELBOW (SOLDER)	6-D
7	1 1/2" SERVICE FITTING (MIP x C110) OR 2" SERVICE FITTING (MIP x C110)	6-D
8	2" ANGLE METER STOP (COMPRESSION x FLG)	2-F
9	METER (FURNISHED AND INSTALLED BY VWD)	13-C
10	1 1/2" OR 2" NIPPLE PER RESPECTIVE METER SIZE, 4" LENGTH	6-D
11	1 1/2" OR 2" BALL VALVE PER RESPECTIVE METER SIZE	2-I
12	METER BOX SIZE (17"W x 30"L x 12"D)	9-E
13	1 1/2" OR 2" FLANGE ADAPTOR (FLG x FIP) PER RESPECTIVE METER SIZE	6-D

CITY OF VICTORVILLE - ENGINEERING DEPARTMENT

REV.	DATE	BY	TYPICAL SERVICE INSTALLATION FOR 1 1/2" AND 2" METERS	W-03
4	9/14/16	STAFF		
3	4/5/16	STAFF		
2	3/12/15	STAFF		
BRIAN W. GENGLER, CITY ENGINEER			SHEET 1 OF 1	